


TRENCH CROSS-SECTION

NOTE:

1. BEDDING SHALL BE IN ACCORDANCE WITH STANDARD 305.
2. SELECT BACKFILL SHALL BE IN ACCORDANCE WITH ODOT 703.01 AGGREGATE BASE TYPE A PLACED IN HORIZONTAL LIFTS NOT TO EXCEED 8 INCHES AND THEN COMPACTED. INITIAL BACKFILL SHALL BE TO THE HAUNCH OF THE PIPE IN HORIZONTAL LIFTS NOT TO EXCEED 8 INCHES AND THEN COMPACTED. COMPACTION PROCEDURE AND RESULTS SHALL BE SUBJECT TO APPROVAL OF THE ENGINEER.
3. SOIL BACKFILL SHALL BE IN ACCORDANCE WITH ODOT 616.04.L BACKFILLING.
4. FOR PAVED AREAS, SEE STANDARD DETAIL FOR PAVEMENT REMOVAL AND REPLACEMENT.
5. COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY PER AASHTO T-99.

TRENCH DETAIL WATERLINE	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2022	APPROVED 
NOT TO SCALE	STANDARD NO. 304A