



NOTE:

1. THE TOP DISCHARGE SHALL BE SET TO DISCHARGE DOWN WITH A BALL VALVE AS SHOWN.
2. ALL MEMBERS MUST BE BRASS OR STAINLESS STEEL.
3. UNIT SHALL BE PLACED IN STANDARD SANITARY SEWER 4' I.D. MANHOLE WITH CAST-IN-PLACE BASE.

| VALVE DIMENSIONS | |
|------------------|--------|
| HEIGHT | 26" |
| WIDTH | 14" |
| DEPTH | 9-1/2" |
| INLET | 2" |
| OUTLET | 2" |

| | |
|--|------------------|
| STANDARD DETAIL SANITARY SEWER COMBINATION AIR RELIEF VALVE INSTALLATION | |
| CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT | |
| DRAWN BY: R.M.O. | APPROVED |
| CHECKED BY: <i>HA</i> | <i>Kalish</i> |
| DATE: MARCH 2022 | |
| NOT TO SCALE | STANDARD NO. 364 |