


45° TAP



SIDE TAP

NOTE:

1. SERV. CLAMP REQUIRED FOR ALL SIZES PVC, AND FOR 4" AND SMALLER IRON. FOR 6" AND LARGER IRON, TAP DIRECTLY.
2. TAP AT ANGLE NECESSARY TO PROVIDE 30° OF COVER OVER THE SERVICE LINE.
3. COPPER SERVICE LINES SHALL BE TYPE K SOFT ANNEALED.

STANDARD METER SETTINGS FOR 5/8" X 3/4" AND 3/4" WATER SERVICE	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2023	APPROVED <i>[Signature]</i>
NOT TO SCALE	STANDARD NO. 501