


INSTALL PIPE TO MANHOLE AS DESCRIBED IN SECTION 315.3 OF THE CITY OF TULSA CONSTRUCTION SPECIFICATIONS

**NOTE:**

1. HDPE 90 TO BE MANUFACTURED BY GEORGE FISCHER CENTRAL PLASTICS SHAWNEE, OK WITH DR 11 PE4710 HDPE PIPE MEETING ASTM F714/D3035 AWWA C901/C906
2. HDPE TEE TO BE MANUFACTURED BY GEORGE FISCHER CENTRAL PLASTICS SHAWNEE, OK WITH DR11 PE4710 HDPE PIPE MEETING ASTM D2513/D3261, AWWA C906.
3. HDPE ELECTRO-FUSION COUPLING TO BE MANUFACTURED BY GEORGE FISCHER CENTRAL PLASTICS BASED OUT OF SHAWNEE, OK
4. HDPE PIPE SHALL MEET SECTION 408 OF CITY STANDARD SPECIFICATIONS.

STANDARD DETAIL DROP DETAIL FOR PIPE BURST LINE	
CITY OF TULSA, OKLAHOMA PUBLIC WORKS DEPARTMENT	
DRAWN BY: D.J.N.	APPROVED: 
CHECKED BY:	
DATE: OCT. 18 2023	
NOT TO SCALE	STANDARD NO. 416