


INSTALL PIPE TO MANHOLE AS DESCRIBED IN SECTION 315.3 OF THE CITY OF TULSA CONSTRUCTION SPECIFICATIONS

NOTE:

1. HDPE 90° TO BE MANUFACTURED BY GEORGE FISCHER CENTRAL PLASTICS SHAWNEE, OK WITH DR 11 PE4710 HDPE PIPE MEETING ASTM F714/D3035 AWWA C901/C906
2. HDPE TEE TO BE MANUFACTURED BY GEORGE FISCHER CENTRAL PLASTICS SHAWNEE, OK WITH DR11 PE4710 HDPE PIPE MEETING ASTM D2513/D3261, AWWA C906.
3. HDPE ELECTRO-FUSION COUPLING TO BE MANUFACTURED BY GEORGE FISCHER CENTRAL PLASTICS BASED OUT OF SHAWNEE, OK
4. HDPE PIPE SHALL MEET SECTION 409 OF CITY STANDARD SPECIFICATIONS.

DROP DETAIL FOR A SLIPLINE WITH A HOST PIPE DIAMETER OF 10' OR GREATER	
CITY OF TULSA, OKLAHOMA PUBLIC WORKS DEPARTMENT	
DRAWN BY: D.J.N. CHECKED BY: DATE: OCT. 18 2023	APPROVED 
NOT TO SCALE	STANDARD NO. 418